

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Pinewood Springs WD Failed to Implement Significant Deficiency Corrective Action(s)

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

Our water system recently violated a drinking water requirement. Although this situation is not an emergency, as our customers you have a right to know what happened, what you should do, and what we are doing to correct this situation.

A routine drinking water inspection conducted on August 15, 2025 by the state drinking water program identified significant deficiencies that may pose a risk to public health. We were required to take action to correct these deficiencies; however, we failed to take action by the required deadline.

Significant Deficiency	Required Completion Date	Steps We Are Taking	Estimated Completion Date
T310 - Facility ID: 040 - Storage Condition Prior to EP - The condition of the storage structure may allow potential sources of contamination to enter the tank.	January 20, 2026	The district has engaged an Engineer to start the process of replacing the clear well with construction to start in 2027.	12/31/27
D250 - Facility ID: DS001 - High Leakage Rates - Supplier usage data indicated that leakage rates may pose a risk of back-siphonage	January 20, 2026	The district has begun a water line replacement program that will replace 25% of the districts water lines by 2027.	12/31/27
D400 - Facility: DS001 - Line Flushing Program - System lacked an adequate line flushing program or the flushing program can be improved.	January 20, 2026	The district will begin to return to a flushing program with completion of the 25% line replacement, as well as documenting flushing activities as they occur.	12/31/27

- An uncorrected significant deficiency may allow contaminants or disease-causing organisms to enter the drinking water, which can cause diarrhea, nausea, cramps, and associated headaches.

What does this mean? What should I do?

- You do not need to boil your water or take other actions. However, if you have

specific health concerns, consult your doctor.

- If you have an infant, severely compromised immune system, are pregnant, or are elderly, you may be at increased risk and should seek advice from your doctor about drinking this water. General guidelines on ways to lessen the risk of infection by bacteria and other disease-causing organisms are available from EPA's Safe Drinking Water Hotline at 1-800-426-4791.

We anticipate resolving the problem by **ASAP**. For more information, please contact **Gabi Benson** at pswdadmin@att.net or **303-823-5345**, or **183 Cree Ct., Lyons, CO 80540**.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by: Pinewood Springs WD - CO0135610
Date distributed: **2-5-26**