

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Pinewood Springs WD

High Levels of Total Haloacetic Acids (HAA5) and High Levels of Total Trihalomethanes (TTHM)

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

Our water system recently violated a drinking water requirement. Although this situation is not an emergency, as our customers you have a right to know what happened, what you should do, and what we are doing to correct this situation.

- We routinely monitor for the presence of drinking water contaminants. On 09/03/2024 we were notified that our system exceeds the maximum contaminant level (MCL) for Total Trihalomethanes (TTHM). The MCL is 80 ug/L. The average level over the last year was 131 ug/L.
- We routinely monitor for the presence of drinking water contaminants. On 09/03/2024 we were notified that our system exceeds the maximum contaminant level (MCL) for Total Haloacetic Acids (HAA5). The MCL is 60 ug/L. The average level over the last year was 92 ug/L.

What does this mean? What should I do?

- **You do not need to boil your water or take other actions. However, if you have specific health concerns, consult your doctor.**
- Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.
- If you have an infant, severely compromised immune system, are pregnant, or are elderly, you may be at increased risk and should seek advice from your doctor about drinking this water. General guidelines on ways to lessen the risk of infection by bacteria and other disease-causing organisms are available from EPA's Safe Drinking Water Hotline at 1-800-426-4791.

What is being done?

- We are currently in the process of getting tank mixers approved and installed and are also currently consulting with an engineering firm on further actions that can be taken to reduce DBPs in the system.

We anticipate resolving the problem by **As soon as possible**. For more information, please contact **Gabriele Benson** at pswdadmin@att.net or **303-823-5345**, or **183 Cree Ct., Lyons, CO 80540**.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by: Pinewood Springs WD - CO0135610
Date distributed: **10/07/2024**